



GOVT. OF ODISHA
OFFICE OF THE DEPUTY EXECUTIVE ENGINEER
RURAL WORKS SUB-DIVISION, SOHELA

Email ID : rwsohela@gmail.com

Letter No...115.....

Date...13/05/2021.....

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team inspected the "Kendriya Vidyalaya" Dang Chowk, Po-Bardol, Dist-Bargarh on dated 10.05.2021 and found that the "Kendriya Vidyalaya" has providing safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in school building & the campus as per the norms prescribed by the Central/State/UT Govt.

WATER QUALITY REPORT

Source

1. Direct bore well
2. Water Tank

| Items | Quantity | Remarks |
|----------|------------|---------|
| Chloride | 49mg/ltr | Safe |
| Fluoride | 0.92mg/ltr | Safe |
| Iron | 0.53mg/ltr | Safe |
| TDS | 236mg/ltr | Safe |
| Bacteria | Nil | Safe |

The PH value found is in the range of 7.00 which is safe.

The above is valid for a period of one year.


13/5/21
Deputy Executive Engineer
R.W. Sub-Division, Sohela

Deputy Executive Engineer
R.W. Sub - Division, Sohela